

TEST REPORT N°
TIQG-19-009

Standards references	EN 15502-1:2012 + A1:2015 EN 15502-2-1:2012 + A1:2016
Laboratory name	IMQ Spa Via dell'Industria 55, 31020 Zoppè - San Vendemiano Tel. (+39) 0438 470255 / 778358
Testing location	IMQ Spa Via dell'Industria 55, 31020 Zoppè - San Vendemiano Tel. (+39) 0438 470255 / 778358
Applicant	ONMETAL DOKUM SAN. VE TIC. LTD. STI.
Applicant's address	İkitelli O.S.B. 17. Cad. No:5 34306 Başakşehir/ İstanbul - TURKEY
Manufacturer	ONMETAL DOKUM SAN. VE TIC. LTD. STI.
Factory's address	Organize Sanayi Bölgesi Mah. 4. Cad. No:3 Süloğlu/ Edirne - TURKEY
Type of appliance tested	Floor standing boiler
Trade mark	RIMA
Model	ONGAS 303 ONGAS 304 ONGAS 304 PLUS ONGAS 305 ONGAS 306 ONGAS 307
Sampling method	Chosen by the manufacturer
Gas category	See enclosure
Installation type	B23 - C63
Date of issue	2019/10/03
Total number of pages	88 pages
N° of enclosures	1 enclosure
Compiled by	B. Biricik
Approved by	G. Granzotto
General disclaimer	<p><i>The results of tests and checks reported in this Test Report refer exclusively to the samples tested and described in the Report itself.</i></p> <p><i>This report shall not be reproduced partially without the written approval of IMQ S.p.A..</i></p> <p><i>The authenticity of this Test Report and its contents can be verified by contacting IMQ S.p.A., responsible for this Test Report.</i></p>

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

Note Generali
General Note

- Le incertezze di misura dichiarate in questo documento sono state espresse come incertezza estesa ottenuta moltiplicando l'incertezza tipo composta per un fattore di copertura $k=2$ corrispondente ad un livello di fiducia di circa il 95%.
Vedi allegato n°1 per incertezze strumentali
*The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor $K=2$ corresponding to a confidence level of about 95%.
See enclosure n°1 for the equipment uncertainty*

- I campioni oggetto delle prove sono stati prelevati e consegnati dal fabbricante.
The samples tested have been taken and delivered by the manufacuter.

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

Elenco prove
Test list

Standard: EN 15502-1:2012 + A1:2015
EN 15502-2-1:2012 + A:2016

Clause	Test
8.2.1	Soundness of the gas circuit
9.2 - 9.3	USEFUL EFFICIENCIES
8.4.1	Nominal heat input
8.12.3.1	Carbon monoxide - Incomplete combustion
8.12.3.2	Carbon monoxide - Supplementary test for fan assisted boilers
8.12.3.3	Carbon monoxide - Flame Lift
8.4.3	Ignition rate
8.5	Limiting temperatures
8.6	Ignition, cross lighting, flame stability
8.7	Reduction of the gas pressure
8.11.4	Control devices
8.11.5	Ignition devices
8.11.6	Flame supervision device
8.11.8	Thermostats and water temperature limiting devices
8.11.101	Air proving device
8.12.4	Sooting
8.12.5	Carbon monoxide - Supplementary test for low temperature boilers and condensing boilers
8.16	Temperature of combustion products
10	Electric auxiliary energy

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 303

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 303
Installation type admitted	B23 - C63 - C13x - C33x
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	160 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 303

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	65,0
Minimum		kW	15,0
Nominal heat OUTPUT			
Maximum		kW	62,0
Minimum		kW	14,1
Efficiency			
Maximum heat input	(80-60°C)	%	96,2
Minimum heat input	(80-60°C)	%	93,7
Maximum heat input	(50-30°C)	%	106,4
Minimum heat input	(50-30°C)	%	107,1
Partial load return 30°C (direct method)		%	105,8
<hr/>			
Fan speed			MAX MIN
G20		rpm	4950 1300
CO2 content			
			MAX MIN
G20		%	9,70 9,50

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 303

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23 -C63-C13x-C33x
Diameter of air inlet ducts	mm	50,0
Diameter of evacuation ducts	mm	80,0
Maximum Δp pressure ducts	Pa	260

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 303

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL	Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1 Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2 Carbon monoxide - Limit conditions	
8.12.3 Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23												
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	seperated												
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	80 mm												
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	50 mm												
Test n°	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
Test date																	
Ambient temperature	°C	24,8	24,9						24,8	24,9						24,8	24,9
Ambient air speed	m/s	0,18	0,18						0,19	0,18						0,18	0,17
Evacuation duct length	m	1,0	1,0						1,0	1,0						1,0	1,0
Air inlet duct length	m	----	----						----	----						----	----
Δp pressure ducts	Pa																
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,3	20,0													17,0	20,0
Gas meter pressure	mbar	20,4	21,7													17,2	20,3
Fan speed	g/min	4950	1300														2700
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,46	34,46							40,91	40,91					31,46	34,46
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,572	0,572							0,687	0,687					0,586	0,572
Atmospheric pressure	mbar	1013	1013														1013
Gas temperature	°C	25,6	25,8														25,9
Gas meter type a=wet, s=dry		s	s														s
Combustion air temperature	°C	24,8	24,9														24,9
Correction under reference conditions		1,0254	1,0265														1,0250
Meter correction		0,993	0,995														0,991
Gas volume	dm ³	170,0	41,5														150,0
Time	s	92,5	96,1														96,5
Measured heat input	kW	63,67	15,00														53,74
Measured heat input uncertainty	kW																
Nominal heat input	kW	65,00	15,00	65,00	15,00	65,00	15,00	65,00	15,00	65,00	15,00	65,00	15,00	65,00	15,00	15,00	55,00
Deviation		-2,05%	0,01%														-2,30%
Deviation with uncertainty		-2,05%	0,01%														-2,30%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0
Flue gas temperature	°C	85,0	65,0							74,5	65,2						64,3
CO ₂ measured	%	9,7	9,5	10,2	10,0					10,5	10,3	9,6	9,2	10,0	9,0	8,5	
CO measured	ppm	88	13	192	11					190	11	80	13	135	13	15	
CO in dry air-free products combustion products	ppm	106	16	220	13					221	13	98	17	158	17	20	
CO uncertainty	ppm	30	30	30	30					30	30	30	30	30	30	30	
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----
Test n° Pt	Description																
1 8.4.1	Maximum heat input																
2 8.4.1	Minimum heat input																
3 8.12.2.102 b)	"Throttle" maladjustment for CO ₂ 0,5% higher - Q _{max}																
4 8.12.2.102 b)	"Throttle" maladjustment for CO ₂ 0,5% higher - Q _{min}																
5 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Q _{max}																
6 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Q _{min}																
7 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Q _{max}																
8 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Q _{min}																
9 8.12.3.1	Incomplete combustion - Q _{max}																
10 8.12.3.1	Incomplete combustion - Q _{min}																
11 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Q _{max}																
12 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Q _{min}																
13 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Q _{max}																
14 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Q _{min}																
15 8.12.3.3	Flame lift limit gas																
16 8.4.3	Ignition rate																

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 303

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	65,0	kW	Maximum heat output	65,0	kW
Minimum heat input	15,0	kW	Minimum heat output	15,0	kW
Average heat input	40,0	kW	Average heat output	40,0	kW
Range rated	yes				
Type of boiler	condensing				
Type of gas	G20		<u>Parameter for partial load test</u>		
Installation type	B23		Method	direct	
Evacuation duct diameter	80	mm	Operating mode	1,0	
Air inlet duct diameter	50	mm	Conditions	3,0	
Evacuation duct length	0,5	m	T _{ON}	480,0	sec
Air inlet duct length	0,5	m	T _{OFF}	120,0	sec
Diaphragm diameter	----	mm			

Test n°			1	2	3	4	5	6
Ambient temperature	°C		22,8	22,9	22,7	22,5	22,4	22,7
Specific humidity	g/kg		9,7	9,7	9,7	9,7	9,7	9,7
Atmospheric pressure	(Pa)	mbar	1009	1009	1009	1009	1009	1009
Net calorific value of used gas	(Hi)	MJ/m ³ st	34,02	34,02	34,02	34,02	34,02	34,02
Gas meter pressure	(Pg)	mbar	21,7	20,5	21,3	21,6	20,5	20,5
Gas temperature	(Tg)	°C	22,1	22,0	22,3	22,2	22,5	22,6
Gas meter correction			0,994	0,997	0,994	0,988	0,997	0,998
Gas volume		l	1160,0	264,3	710,0	1170,0	271,1	215,4
Time		s	601,7	604,4	605,4	601,4	605,5	600,0
Measured heat input		kW	64,73	14,72	39,33	64,90	15,04	12,07
Loss at test bench	(Dp)	kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate		kg/h	2696,6	600,3	1618,5	2988,9	690,5	1594,6
Return temperature		°C	60,1	59,8	59,7	30,0	30,0	30,1
Flow temperature		°C	80,3	79,9	80,0	49,9	50,1	37,0
ΔT measured			20,2	20,1	20,3	19,9	20,1	6,9
Power issued to water		kW	62,26	13,79	37,56	69,02	16,11	12,77
Water efficiency		%	96,2	93,7	95,5	106,4	107,1	105,8

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	80/50	mm
Evacuation duct length	1,0	m
Air inlet duct length	----	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	x
Start up supervision	

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	9,9%	9,7%
CO2 MIN	9,5%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
	0	5,9	71	141	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
	0	7,3	30	48	2000
					2000
					2000
					2000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
	>900	9,3	19	24	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
	>900	7,5	30	47	2000
					2000
					2000
					2000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					2000
					2000
					2000
					2000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					2000
					2000
					2000
					2000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	80/50	mm
Evacuation duct length	1,0	m
Air inlet duct length	----	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	x
Start up supervision	

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,9%	9,7%
CO ₂ MIN	9,5%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	0	8,5	42	58	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	0	7,8	49	74	2000
					2000
					2000
					2000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	>900	8,2	47	67	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	>900	8,2	52	74	2000
					2000
					2000
					2000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated	Gas group	2E
Duct diameter (evacuation / air inlet)	80/50 mm	Reference gas	G20
Evacuation duct length	1,0 m	Nominal supply pressure	20 mbar
Air inlet duct length	----- m		

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,9%	9,7%
CO ₂ MIN	9,5%	9,3%

Manufacturer choice:

Continuous supervision	x
Start up supervision	

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	0	10,0	22	26	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	0	8,4	31	43	2000
					2000
					2000
					2000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	>900	8,6	32	44	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
	>900	7,8	26	39	2000
					2000
					2000
					2000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 303

8.13 NO_x EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH₂O/kg air)
 8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Q _n	65,0	kW
Minimum heat input	Q _r	15,0	kW
Average heat input	Q _a	40,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	80 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	21,9	°C
Atmospheric pressure	P _{atm}	1009	mbar
Specific humidity		9,46	g/kg

			Q _r			
Partial heat input Q _{pi} in % of Q _n			70%	60%	40%	38%
Partial heat input	Q _{pi}	kW	28,0	24,0	16,0	15,0
Pondering factor	F _{pi}		0,15	0,25	0,30	0,30
Fan speed		g/min	2850	2450	1650	1600
Measured heat input		kW	28,7	24,5	16,3	15,4
Inlet temperature		°C	48,0	44,0	36,0	35,0
CO ₂ measured		%	9,2	9,1	9,0	9,0
CO measured		ppm	50	46	26	20
CO _c (0% O ₂)		ppm	64	59	34	26
NO _x measured		ppm	18	12	8	8
NO _x adjusted		mg/kWh	40,38	27,22	18,35	18,35
NO _x total		mg/kWh	23,87			
NO_x adjusted		mg/kWh	22,18			
NO_x class assigned			5			

NO _x class		1	2	3	4	5
NO _x limit	mg/kWh	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO₂} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H₂O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
<u>MAX HEAT INPUT</u>	65,0 kW						
G20		1,19	1	2	9,7	6,878	28,01
G25		1,19	0,86	1,72	-----	8,000	-----
G30		1,19	4	5	-----	2,016	-----
G31		1,19	3	4	-----	2,659	-----
<u>MIN HEAT INPUT</u>	15,0 kW						
G20		1,19	1	2	9,5	1,587	6,58
G25		1,19	0,86	1,72	-----	1,846	-----
G30		1,19	4	5	-----	0,465	-----
G31		1,19	3	4	-----	0,614	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input -----					
Minimum heat input -----					
----- 2000					
----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input -----					
Minimum heat input -----					
----- 2000					
----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet					
✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,6 390 430 2000					
Minimum heat input (only for gas/air ratio controls) 10,2 30 34 2000					
Intervention of APS before CO concentration exceed 2000ppm -----					
----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

8.5 LIMITING TEMPERATURES

	Measured	Limit
8.5 Limiting temperatures		
8.5.1 Reference gas - Nominal heat input Control thermostat set at maximum The temperature are measured when thermal equilibrium is reached		
Ambient temperature	22,0 °C	
8.5.2 Adjusting, control and safety devices		
Gas valve	32,0 °C	70 °C
Electronic PCB	35,0 °C	60 °C
Knobs		
Metal	----- K	35 K
Glass and ceramics	----- K	45 K
Plastic	4,0 K	60 K
8.5.3 Side walls, front and top surface		
Side wall	9,0 K	80 K
Front surface	8,0 K	80 K
Top surface	7,0 K	80 K
8.5.4 Test panels and floor		
Floor	x K	80 K *
Right panel	2,0 K	80 K *
Left panel	2,0 K	80 K *
Back panel	3,0 K	80 K *
* if temperature rise is between 60 K and 80 K the manufacturer shall supply a protection		
8.5.101 External temperature of the ducts The temperature are measured after 30 min		
External temperature of the ducts	42,0 K	60 K

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 303

10 ELECTRIC AUXILIARY ENERGY

	Unit	Measured
<p>10.2 The system boundary contains all electrical components between the manual shut-off device and the flue outlet of the combustion circuit, <u>including the circulation pump.</u></p>		
<p>10.3 Auxiliary energy at nominal heat input</p> <p>Test conditions as pt. 9.2.2 The external hydraulic resistance is adjusted in such a way that is 0,15 bar at 20 K temperature difference</p>		
<u>Measured auxiliary energy</u>	kW	0,1880
<p>10.4 Auxiliary energy at part load</p> <p>Test conditions as pt. 9.2.2 and 9.3.2</p>		
<u>Measured auxiliary energy</u>	kW	0,0306
<p>10.5 Auxiliary energy at stand-by</p> <p>Power input measured during operation in stand-by</p>		
<u>Measured auxiliary energy</u>	kW	0,0037

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 304
Installation type admitted	B23-C63
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	190 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	90,0
Minimum		kW	20,0
Nominal heat OUTPUT			
Maximum		kW	87,8
Minimum		kW	18,9
Efficiency			
Maximum heat input	(80-60°C)	%	97,6
Minimum heat input	(80-60°C)	%	94,7
Maximum heat input	(50-30°C)	%	104,8
Minimum heat input	(50-30°C)	%	108,3
Partial load return 30°C (direct method)		%	105,3
<hr/>			
Fan speed			MAX MIN
G20		rpm	6200 1500
<hr/>			
CO2 content			MAX MIN
G20		%	9,60 9,10

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 304

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23-C63
Diameter of air inlet ducts	mm	80,0
Diameter of evacuation ducts	mm	100,0
Maximum Δp pressure ducts	Pa	260

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL	Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1 Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2 Carbon monoxide - Limit conditions	
8.12.3 Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	seperated
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	100 mm
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	80 mm

Test n°		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Test date																	
Ambient temperature	°C	23,1	22,9							23,1	22,9					23,1	23,0
Ambient air speed	m/s	0,18	0,19							0,19	0,18					0,18	0,18

Evacuation duct length	m	0,5	0,5							0,5	0,5					1,0	1,0
Air inlet duct length	m	----	----							----	----					----	----
Δp pressure ducts	Pa																
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,0	20,0														17,0
Gas meter pressure	mbar	26,0	21,0														18,0
Fan speed	g/min	6200	1500														1500
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,02	34,02							40,91	40,91					28,91	
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,555	0,555							0,687	0,687					0,617	
Atmospheric pressure	mbar	1011	1011													1011	
Gas temperature	°C	22,1	22,9													22,8	
Gas meter type	a=wet, s=dry	s	s													s	
Combustion air temperature	°C	60,6	56,3														x
Correction under reference conditions		1,0116	1,0059														0,9694
Meter correction		0,993	0,994														0,994
Gas volume	dm ³	480,0	110,0														110,0
Time	s	181,4	184,8														194,2
Measured heat input	kW	90,42	20,26														16,33
Measured heat input uncertainty	kW																
Nominal heat input	kW	90,00	20,00	90,00	20,00	90,00	20,00	90,00	20,00	90,00	20,00	90,00	20,00	90,00	20,00	20,00	
Deviation		0,47%	1,30%														-18,35%
Deviation with uncertainty		0,47%	1,30%														-18,35%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0

Flue gas temperature	°C	84,0	41,0														
CO2 measured	%	9,6	9,1							10,8		9,4	9,1	9,6	9,1	7,4	
CO measured	ppm	140	16							305		84	16	140	14	8	
CO in dry air-free products combustion products	ppm	171	21							345		105	21	171	18	12	
CO uncertainty	ppm	30	30									30	30	30	30	30	
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----

Test n° Pt	Description
1 8.4.1	Maximum heat input
2 8.4.1	Minimum heat input
3 8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmax
4 8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmin
5 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmax
6 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmin
7 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmax
8 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmin
9 8.12.3.1	Incomplete combustion - Qmax
10 8.12.3.1	Incomplete combustion - Qmin
11 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmax
12 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmin
13 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmax
14 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmin
15 8.12.3.3	Flame lift limit gas
16 8.4.3	Ignition rate

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	90,0	kW	Maximum heat output	90,0	kW
Minimum heat input	20,0	kW	Minimum heat output	20,0	kW
Average heat input	55,0	kW	Average heat output	55,0	kW
Range rated	yes				
Type of boiler	condensing				

Type of gas	G20	
Installation type	B23	
Evacuation duct diameter	100	mm
Air inlet duct diameter	80	mm
Evacuation duct length	0,5	m
Air inlet duct length	----	m
Diaphragm diameter	----	mm

<u>Parameter for partial load test</u>		
Method	direct	
Operating mode	1,0	
Conditions	3,0	
T _{ON}	495,0	sec
T _{OFF}	105,0	sec

Test n°			1	2	3	4	5	6
Ambient temperature	°C		23,3	23,3	23,3	23,2	23,2	23,0
Specific humidity	g/kg		9,8	9,8	9,8	9,8	9,8	9,8
Atmospheric pressure	(Pa)	mbar	1011	1011	1011	1011	1011	1011
Net calorific value of used gas	(Hi)	MJ/m ³ st	34,02	34,02	34,02	34,02	34,02	34,02
Gas meter pressure	(Pg)	mbar	25,7	21,1	23,4	26,0	21,0	21,5
Gas temperature	(Tg)	°C	22,7	22,8	22,7	22,7	22,5	22,4
Gas meter correction			0,994	0,994	0,996	0,993	0,994	0,997
Gas volume		l	1620,0	360,0	960,0	1600,0	360,0	290,0
Time		s	602,9	609,7	601,0	601,1	599,2	602,2
Measured heat input		kW	90,55	19,80	53,82	89,63	20,17	16,23
Loss at test bench	(Dp)	kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate		kg/h	3826,0	816,2	2240,7	3986,8	936,5	2164,1
Return temperature		°C	60,2	60,0	59,8	29,9	30,0	30,3
Flow temperature		°C	80,4	80,1	80,0	50,2	50,1	37,1
ΔT measured			20,2	20,1	20,2	20,3	20,1	6,8
Power issued to water		kW	88,33	18,75	51,74	93,92	21,84	17,07
Water efficiency	%		97,6	94,7	96,1	104,8	108,3	105,3

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

*General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty*

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	100/80	mm
Evacuation duct length	0,5	m
Air inlet duct length	0,5	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	9,8%	9,3%
CO2 MIN	9,4%	8,9%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,1	16	21	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		8,7	44	59	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,7	23	28	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,5	78	96	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated
Duct diameter (evacuation / air inlet)	100/80 mm
Evacuation duct length	0,5 m
Air inlet duct length	0,5 m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,8%	9,3%
CO ₂ MIN	9,4%	8,9%

a) Progressive blockage of the air inlet

Maximum heat input					
Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
		10,6	459	507	1000
					1000
					1000
					1000

Minimum heat input					
Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
		9,7	345	416	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Maximum heat input					
Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
		9,5	732	902	1000
					1000
					1000
					1000

Minimum heat input					
Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
		8,3	497	701	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Maximum heat input					
Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Minimum heat input					
Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	CO _c (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	100/80	mm
Evacuation duct length	0,5	m
Air inlet duct length	0,5	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,8%	9,3%
CO ₂ MIN	9,4%	8,9%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,7	695	838	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,5	298	367	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,4	670	834	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		7,9	395	585	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304

8.13 NOx EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH2O/kg air)
 8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Qn	90,0	kW
Minimum heat input	Qr	20,0	kW
Average heat input	Qa	55,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	100-80 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	20,9	°C
Atmospheric pressure	P _{atm}	1011	mbar
Specific humidity		9,5	g/kg

				Qr			
Partial heat input Qpi in % of Qn				70%	60%	40%	36%
Partial heat input	Qpi	kW		38,5	33,0	22,0	20,0
Pondering factor	Fpi			0,15	0,25	0,30	0,30
Fan speed		g/min		2800	2450	1700	1500
Measured heat input		kW		38,2	33,3	22,4	20,3
Inlet temperature		°C		48,0	44,0	36,0	34,5
CO ₂ measured		%		9,5	9,4	9,1	9,1
CO measured		ppm		32	30	20	18
COc (0% O ₂)		ppm		39	37	26	23
NOx measured		ppm		19	18	8	8
NOx adjusted		mg/kWh		41,28	39,52	18,14	18,14
NOx total		mg/kWh		26,96			
NOx adjusted		mg/kWh		26,10			
NOx class assigned				5			

NOx class	1	2	3	4	5
NOx limit mg/kWh	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO2} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H2O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
MAX HEAT INPUT		90,0 kW					
	G20	1,19	1	2	9,6	9,524	39,12
	G25	1,19	0,86	1,72	-----	11,077	-----
	G30	1,19	4	5	-----	2,791	-----
	G31	1,19	3	4	-----	3,682	-----
MIN HEAT INPUT		20,0 kW					
	G20	1,19	1	2	9,1	2,116	9,09
	G25	1,19	0,86	1,72	-----	2,462	-----
	G30	1,19	4	5	-----	0,620	-----
	G31	1,19	3	4	-----	0,818	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet ✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,7 360 394 2000					
Minimum heat input (only for gas/air ratio controls) 10,3 24 27 2000					
Intervention of APS before CO concentration exceed 2000ppm ----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304PLUS

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 304Plus
Installation type admitted	B23-C63
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	188 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304PLUS

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	110,0
Minimum		kW	20,0
Nominal heat OUTPUT			
Maximum		kW	107,0
Minimum		kW	19,5
Efficiency			
Maximum heat input	(80-60°C)	%	97,3
Minimum heat input	(80-60°C)	%	97,7
Maximum heat input	(50-30°C)	%	106,2
Minimum heat input	(50-30°C)	%	109,9
Partial load return 30°C (direct method)		%	103,0
<hr/>			
Fan speed			MAX MIN
G20		rpm	5500 1100
CO2 content			
			MAX MIN
G20		%	9,80 9,70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 304PLUS

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23-C63
Diameter of air inlet ducts	mm	60,0
Diameter of evacuation ducts	mm	100,0

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304PLUS

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL	Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1 Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2 Carbon monoxide - Limit conditions	
8.12.3 Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	seperated
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	100 mm
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	60 mm

Test n°		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Ambient temperature	°C	21,9	21,9														
Ambient air speed	m/s	0,18	0,18														
Evacuation duct length	m	1,0	1,0														
Air inlet duct length	m	1,0	1,0														
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,0	20,0													17,0	20,0
Gas meter pressure	mbar	19,6	21,6													17,2	20,3
Fan speed	g/min	5500	1100														1700
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,10	34,10														34,10
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,572	0,572														0,572
Atmospheric pressure	mbar	1014	1014														1012
Gas temperature	°C	21,9	21,9														26,0
Gas meter type	a=wet, s=dry	s	s														s
Combustion air temperature	°C	21,9	21,9														26,0
Correction under reference conditions		1,0260	1,0279														1,0267
Meter correction		0,993	0,995														0,994
Gas volume	dm ³	150,0	50,0														70,0
Time	s	46,7	84,3														71,3
Measured heat input	kW	111,35	20,65														34,09
Measured heat input uncertainty	kW																
Nominal heat input	kW	110,00	20,00	110,00	20,00	110,00	20,00	110,00	20,00	110,00	20,00	110,00	20,00	110,00	20,00	20,00	34,00
Deviation		1,23%	3,25%														0,25%
Deviation with uncertainty		1,23%	3,25%														0,25%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0

Flue gas temperature	°C	85,0	42,3														
CO2 measured	%	9,8	9,7	9,9	10,3					10,5	10,5						7,4
CO measured	ppm	187	6	156	9					271	48						6
CO in dry air-free products combustion products	ppm	223	7	184	10					315	56						9
CO uncertainty	ppm	30	30	30	30					30	30						30
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----

Test n°	Pt	Description
1	8.4.1	Maximum heat input
2	8.4.1	Minimum heat input
3	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmax
4	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmin
5	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmax
6	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmin
7	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmax
8	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmin
9	8.12.3.1	Incomplete combustion - Qmax
10	8.12.3.1	Incomplete combustion - Qmin
11	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmax
12	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmin
13	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmax
14	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmin
15	8.12.3.3	Flame lift limit gas
16	8.4.3	Ignition rate

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304PLUS

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	110,0	kW	Maximum heat output	110,0	kW
Minimum heat input	20,0	kW	Minimum heat output	20,0	kW
Average heat input	65,0	kW	Average heat output	65,0	kW
Range rated	yes				
Type of boiler	condensing				

Type of gas	G20		<u>Parameter for partial load test</u>		
Installation type	B23		Method	direct	
Evacuation duct diameter	100	mm	Operating mode	1,0	
Air inlet duct diameter	60	mm	Conditions	2,0	
Evacuation duct length	0,2	m	T _{ON}	600,0	sec
Air inlet duct length	0,2	m	T _{OFF}	0,0	sec
Diaphragm diameter	----	mm			

Test n°			1	2	3	4	5	6
Ambient temperature	°C		24,2	25,3	24,3	23,0	24,5	22,3
Specific humidity	g/kg		6,3	6,9	7,0	7,3	6,0	6,4
Atmospheric pressure	(Pa)	mbar	1015	1019	1020	1020	1020	1021
Net calorific value of used gas	(Hi)	MJ/m ³ st	34,10	34,10	34,10	34,10	34,10	34,10
Gas meter pressure	(Pg)	mbar	24,3	27,5	26,1	24,5	27,5	29,5
Gas temperature	(Tg)	°C	24,2	24,5	24,3	22,5	22,8	21,8
Gas meter correction			0,993	0,993	0,994	0,993	0,995	0,995
Gas volume		l	1470,0	440,0	1130,0	1910,0	370,0	330,0
Time		s	458,9	783,6	599,8	602,5	642,1	607,2
Measured heat input		kW	107,79	19,01	63,87	107,87	19,68	18,67
Loss at test bench	(Dp)	kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate		kg/h	4653,2	818,1	2740,3	4765,1	931,7	4700,7
Return temperature		°C	60,1	60,8	60,4	30,1	29,7	30,1
Flow temperature		°C	79,5	80,3	80,4	50,8	49,6	33,6
ΔT measured			19,4	19,5	20,0	20,6	19,9	3,5
Power issued to water		kW	104,81	18,57	63,79	114,20	21,57	19,19
Water efficiency	%		97,3	97,7	99,9	106,1	109,9	103,0
Water efficiency uncertainty	%		1,8	1,8	1,8	1,8	1,8	1,8

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304PLUS

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	100/60	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	10,0%	9,6%
CO2 MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		10,7	270	295	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,7	27	33	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		11,2	114	119	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,8	54	64	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304PLUS

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	100/60	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	10,0%	9,6%
CO ₂ MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		10,9	477	512	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,9	370	437	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,7	750	909	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		8,5	510	702	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304PLUS

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	100/60	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	10,0%	9,6%
CO ₂ MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,9	734	866	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,6	324	395	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,6	684	838	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		8,0	420	614	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 304PLUS

8.13 NOx EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH2O/kg air)

8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Qn	110,0	kW
Minimum heat input	Qr	20,0	kW
Average heat input	Qa	65,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	100-60 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	20,9	°C
Atmospheric pressure	P _{atm}	1011	mbar
Specific humidity		6,1	g/kg

			Qr			
Partial heat input Qpi in % of Qn			70%	60%	40%	31%
Partial heat input	Qpi	kW	45,5	39,0	26,0	20,0
Pondering factor	Fpi		0,15	0,25	0,30	0,30
Fan speed		g/min	2800	2450	1700	1500
Measured heat input		kW	38,2	33,3	22,4	20,3
Inlet temperature		°C	48,0	44,0	36,0	32,3
CO ₂ measured		%	9,4	9,3	9,1	9,0
CO measured		ppm	32	30	20	18
COc (0% O ₂)		ppm	40	38	26	23
NOx measured		ppm	17	18	8	8
NOx adjusted		mg/kWh	37,33	39,95	18,14	18,35
NOx total		mg/kWh	26,53			
NOx adjusted		mg/kWh	25,08			
NOx class assigned			5			

NOx class	1	2	3	4	5
NOx limit	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304PLUS

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO2} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H2O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
<u>MAX HEAT INPUT</u>		110,0 kW					
	G20	1,19	1	2	9,8	11,640	47,00
	G25	1,19	0,86	1,72	-----	13,538	-----
	G30	1,19	4	5	-----	3,411	-----
	G31	1,19	3	4	-----	4,500	-----
<u>MIN HEAT INPUT</u>		20,0 kW					
	G20	1,19	1	2	9,7	2,116	8,62
	G25	1,19	0,86	1,72	-----	2,462	-----
	G30	1,19	4	5	-----	0,620	-----
	G31	1,19	3	4	-----	0,818	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 304PLUS

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input -----					
Minimum heat input -----					
----- 2000					
----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input -----					
Minimum heat input -----					
----- 2000					
----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet					
✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,8 340 368 2000					
Minimum heat input (only for gas/air ratio controls) 10,5 19 21 2000					
Intervention of APS before CO concentration exceed 2000ppm ----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 305

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 305
Installation type admitted	B23-C63
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	188 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 305

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	119,0
Minimum		kW	19,0
Efficiency			
Maximum heat input	(80-60°C)	%	96,4
Minimum heat input	(80-60°C)	%	94,8
Maximum heat input	(50-30°C)	%	104,3
Minimum heat input	(50-30°C)	%	108,0
Partial load return 30°C (direct method)		%	105,7
Injectors identification			MAX MIN
G20	marking	5300	1000
Injectors pressure			MAX MIN
G20	%	9,70	9,20



Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 305

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23-C63
Diameter of air inlet ducts	mm	80,0
Diameter of evacuation ducts	mm	115,0

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 305

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL		Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1	Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2	Carbon monoxide - Limit conditions	
8.12.3	Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	seperated
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	115 mm
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	80 mm

Test n°		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Ambient temperature	°C	26,3	26,3														
Ambient air speed	m/s	0,18	0,19														
Evacuation duct length	m	1,0	1,0														
Air inlet duct length	m	1,0	1,0														
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,0	20,0														20,0
Gas meter pressure	mbar	25,0	28,9														27,2
Fan speed	g/min	5300	1000														2700
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,10	34,10														34,10
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,555	0,555														0,556
Atmospheric pressure	mbar	1018	1018														1018
Gas temperature	°C	24,5	24,1														23,7
Gas meter type	a=wet, s=dry	s	s														s
Combustion air temperature	°C	26,3	26,3														26,5
Correction under reference conditions		1,0190	1,0235														1,0237
Meter correction		0,993	0,995														0,994
Gas volume	dm ³	300,0	100,0														100,0
Time	s	87,4	190,2														56,6
Measured heat input	kW	118,16	18,22														61,16
Measured heat input uncertainty	kW																
Nominal heat input	kW	119,00	19,00	119,00	19,00	119,00	19,00	119,00	19,00	119,00	19,00	119,00	19,00	119,00	19,00	119,00	60,00
Deviation		-0,71%	-4,13%														1,94%
Deviation with uncertainty		-0,71%	-4,13%														1,94%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0

Flue gas temperature	°C	72,1	49,1														
CO2 measured	%	9,7	9,2	10,0	9,7					10,7	10,5						7,6
CO measured	ppm	105	24	173	23					293	148						38
CO in dry air-free products combustion products	ppm	127	31	202	28					334	172						58
CO uncertainty	ppm	30	30	30	30					30	30						30
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----

Test n°	Pt	Description
1	8.4.1	Maximum heat input
2	8.4.1	Minimum heat input
3	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmax
4	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmin
5	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmax
6	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmin
7	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmax
8	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmin
9	8.12.3.1	Incomplete combustion - Qmax
10	8.12.3.1	Incomplete combustion - Qmin
11	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmax
12	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmin
13	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmax
14	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmin
15	8.12.3.3	Flame lift limit gas
16	8.4.3	Ignition rate

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 305

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	119,0	kW	Maximum heat output	119,0	kW
Minimum heat input	19,0	kW	Minimum heat output	19,0	kW
Average heat input	69,0	kW	Average heat output	69,0	kW
Range rated	yes				
Type of boiler	condensing				

Type of gas	G20	
Installation type	B23	
Evacuation duct diameter	115	mm
Air inlet duct diameter	80	mm
Evacuation duct length	0,5	m
Air inlet duct length	0,5	m
Diaphragm diameter	----	mm

<u>Parameter for partial load test</u>		
Method	direct	
Operating mode	1,0	
Conditions	4,0	
T _{ON}	20,0	sec
T _{OFF}	580,0	sec

Test n°		1	2	3	4	5	6
Ambient temperature	°C	23,4	23,5	23,5	23,6	23,6	23,3
Specific humidity	g/kg	9,9	9,9	9,9	9,9	9,9	9,9
Atmospheric pressure	(Pa) mbar	1009	1009	1009	1009	1009	1009
Net calorific value of used gas	(Hi) MJ/m ³ st	34,02	34,02	34,02	34,02	34,02	34,02
Gas meter pressure	(Pg) mbar	29,9	21,0	22,6	30,3	21,4	20,6
Gas temperature	(Tg) °C	23,0	22,9	22,9	23,0	23,2	22,9
Gas meter correction		0,998	0,995	0,999	0,998	0,994	0,994
Gas volume	l	1990,0	350,0	1200,0	2060,0	360,0	387,9
Time	s	601,5	616,5	599,8	602,1	613,8	600,6
Measured heat input	kW	112,07	19,01	67,40	115,99	19,62	21,61
Loss at test bench	(Dp) kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate	kg/h	4655,1	792,6	2818,8	5265,9	904,0	2852,2
Return temperature	°C	59,6	59,9	60,0	30,1	30,2	30,4
Flow temperature	°C	79,9	79,8	80,1	49,9	50,4	37,3
ΔT measured		20,3	19,9	20,1	19,8	20,2	6,9
Power issued to water	kW	108,04	18,03	64,76	120,99	21,19	22,83
Water efficiency	%	96,4	94,8	96,1	104,3	108,0	105,7

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 305

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	115/80	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	9,9%	9,5%
CO2 MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		10,3	144	163	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		4,1	37	105	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		5,3	160	353	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		5,9	246	488	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 305

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	115/80	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	x
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,9%	9,5%
CO ₂ MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		11,2	682	716	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		4,8	35	86	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
*		11,3	1813	1877	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		5,8	96	194	1000
					1000
					1000
					1000

* Continuous supervision is applied in this measurement

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 305

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	115/80	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,9%	9,5%
CO ₂ MIN	9,7%	9,3%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,9	125	148	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,1	316	606	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		5,9	127	252	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		5,4	43	93	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 305

8.13 NOx EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH2O/kg air)
 8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Qn	119,0	kW
Minimum heat input	Qr	19,0	kW
Average heat input	Qa	69,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	115-80 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	22,9	°C
Atmospheric pressure	P _{atm}	1009	mbar
Specific humidity		10,24	g/kg

			Qr			
Partial heat input Qpi in % of Qn			70%	60%	40%	28%
Partial heat input	Qpi	kW	48,3	41,4	27,6	19,0
Pondering factor	Fpi		0,15	0,25	0,30	0,30
Fan speed		g/min	2400	2050	1350	1300
Measured heat input		kW	49,3	41,5	28,1	19,5
Inlet temperature		°C	48,0	44,0	36,0	31,0
CO ₂ measured		%	9,6	9,5	9,3	9,1
CO measured		ppm	52	40	24	10
COc (0% O ₂)		ppm	63	49	30	13
NOx measured		ppm	24	18	8	5
NOx adjusted		mg/kWh	51,60	39,11	17,75	11,34
NOx total		mg/kWh	26,24			
NOx adjusted		mg/kWh	23,82			
NOx class assigned			5			

NOx class	1	2	3	4	5
NOx limit	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 305

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO2} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H2O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
MAX HEAT INPUT		119,0 kW					
G20		1,19	1	2	9,7	12,593	51,28
G25		1,19	0,86	1,72		14,646	#DIV/0!
G30		1,19	4	5		3,690	#DIV/0!
G31		1,19	3	4		4,868	#DIV/0!
MIN HEAT INPUT		19,0 kW					
G20		1,19	1	2	9,2	2,011	8,56
G25		1,19	0,86	1,72		2,338	#DIV/0!
G30		1,19	4	5		0,589	#DIV/0!
G31		1,19	3	4		0,777	#DIV/0!

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 305

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet ✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,9 300 322 2000					
Minimum heat input (only for gas/air ratio controls) 10,8 14 15 2000					
Intervention of APS before CO concentration exceed 2000ppm ----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 306

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 306
Installation type admitted	B23-C63
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	188 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 306

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	148,0
Minimum		kW	34,0
Efficiency			
Maximum heat input	(80-60°C)	%	96,0
Minimum heat input	(80-60°C)	%	96,2
Maximum heat input	(50-30°C)	%	103,8
Minimum heat input	(50-30°C)	%	109,4
Partial load return 30°C (direct method)		%	106,1
Fan speed			MAX MIN
G20		rpm	5950 1400
CO2 content			MAX MIN
G20		%	9,40 9,80

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 306

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23-C63
Diameter of air inlet ducts	mm	115,0
Diameter of evacuation ducts	mm	130,0

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 306

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL	Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1 Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2 Carbon monoxide - Limit conditions	
8.12.3 Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	seperated
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	130 mm
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	115 mm

Test n°		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Ambient temperature	°C	24,1	24,5														
Ambient air speed	m/s	0,18	0,19														
Evacuation duct length	m	1,0	1,0														
Air inlet duct length	m	1,0	1,0														
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,0	20,0													17,0	20,0
Gas meter pressure	mbar	23,5	28,0													17,2	24,8
Fan speed	g/min	5950	1400														2700
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,10	34,10														34,10
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,555	0,555														0,555
Atmospheric pressure	mbar	1007	1007														1007
Gas temperature	°C	22,8	22,2														22,5
Gas meter type	a=wet, s=dry	s	s														s
Combustion air temperature	°C	24,1	24,1														24,1
Correction under reference conditions		1,0167	1,0222														1,0184
Meter correction		0,993	0,995														0,994
Gas volume	dm ³	220,0	100,0														100,0
Time	s	50,8	105,1														44,2
Measured heat input	kW	148,77	32,94														77,94
Measured heat input uncertainty	kW																
Nominal heat input	kW	148,00	34,00	148,00	34,00	148,00	34,00	148,00	34,00	148,00	34,00	148,00	34,00	148,00	34,00	34,00	78,00
Deviation		0,52%	-3,13%														-0,08%
Deviation with uncertainty		0,52%	-3,13%														-0,08%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0

Flue gas temperature	°C	59,1	55,0														
CO2 measured	%	9,4	9,8		10,3					10,3	11,6						7,0
CO measured	ppm	73	10		15					693	270						550
CO in dry air-free products combustion products	ppm	91	12		17					818	284						900
CO uncertainty	ppm	30	30		30					30	30						30
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----

Test n°	Pt	Description
1	8.4.1	Maximum heat input
2	8.4.1	Minimum heat input
3	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmax
4	8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmin
5	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmax
6	8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmin
7	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmax
8	8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmin
9	8.12.3.1	Incomplete combustion - Qmax
10	8.12.3.1	Incomplete combustion - Qmin
11	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmax
12	8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmin
13	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmax
14	8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmin
15	8.12.3.3	Flame lift limit gas
16	8.4.3	Ignition rate

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 306

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	148,0	kW	Maximum heat output	148,0	kW
Minimum heat input	34,0	kW	Minimum heat output	34,0	kW
Average heat input	91,0	kW	Average heat output	91,0	kW
Range rated	yes				
Type of boiler	condensing				

Type of gas	G20
Installation type	B23
Evacuation duct diameter	130 mm
Air inlet duct diameter	115 mm
Evacuation duct length	0,5 m
Air inlet duct length	0,5 m
Diaphragm diameter	----- mm

<u>Parameter for partial load test</u>		
Method	direct	
Operating mode	1,0	
Conditions	3,0	
T _{ON}	482,0	sec
T _{OFF}	118,0	sec

Test n°			1	2	3	4	5	6
Ambient temperature	°C		23,8	23,7	23,8	23,5	23,1	23,4
Specific humidity	g/kg		10,1	10,1	10,1	10,1	10,1	10,1
Atmospheric pressure	(Pa)	mbar	1011	1011	1011	1011	1011	1011
Net calorific value of used gas	(Hi)	MJ/m ³ st	34,02	34,02	34,02	34,02	34,02	34,02
Gas meter pressure	(Pg)	mbar	36,0	21,7	26,5	36,0	20,5	22,4
Gas temperature	(Tg)	°C	22,8	23,0	22,9	22,8	22,7	22,4
Gas meter correction			1,002	0,993	0,993	1,000	0,993	0,993
Gas volume		l	2520,0	570,0	1590,0	2540,0	580,0	471,1
Time		s	599,9	602,1	601,3	603,7	607,6	600,2
Measured heat input		kW	114,07	31,72	89,04	144,00	31,98	26,37
Loss at test bench	(Dp)	kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate		kg/h	6143,7	1362,1	3649,6	6345,6	1500,5	3600,5
Return temperature		°C	60,4	60,1	59,4	30,1	29,9	30,1
Flow temperature		°C	80,1	79,7	79,8	50,4	50,0	36,8
ΔT measured			19,7	19,6	20,4	20,3	20,1	6,7
Power issued to water		kW	138,31	30,51	85,13	149,48	35,00	27,99
Water efficiency	%		96,0	96,2	95,6	103,8	109,4	106,1
Water efficiency uncertainty	%							

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 306

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	130/115	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	9,6%	9,2%
CO2 MIN	10,0%	9,6%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		7,2	54	88	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		6,2	27	51	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		8,6	27	37	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		6,2	34	64	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 306

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated	Gas group	2E
Duct diameter (evacuation / air inlet)	130/115 mm	Reference gas	G20
Evacuation duct length	0,2 m	Nominal supply pressure	20 mbar
Air inlet duct length	0,2 m		

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,6%	9,2%
CO ₂ MIN	10,0%	9,6%

Manufacturer choice:

Continuous supervision	
Start up supervision	x

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,4	120	219	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		5,8	107	216	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		9,2	36	46	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		8,9	18	24	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 306

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated
Duct diameter (evacuation / air inlet)	130/115 mm
Evacuation duct length	0,2 m
Air inlet duct length	0,2 m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	x
Start up supervision	

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,6%	9,2%
CO ₂ MIN	10,0%	9,6%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		10,7	278	303	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,3	32	60	2000
					2000
					2000
					2000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		11,3	1625	1683	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,0	47	92	2000
					2000
					2000
					2000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 306

8.13 NOx EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH2O/kg air)
 8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Qn	148,0	kW
Minimum heat input	Qr	34,0	kW
Average heat input	Qa	91,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	130-115 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	23,9	°C
Atmospheric pressure	P _{atm}	1011	mbar
Specific humidity		9,56	g/kg

			Qr			
Partial heat input Qpi in % of Qn			70%	60%	40%	37%
Partial heat input	Qpi	kW	63,7	54,6	36,4	34,0
Pondering factor	Fpi		0,15	0,25	0,30	0,30
Fan speed		g/min	2400	2050	1350	1300
Measured heat input		kW	65,3	55,0	36,0	33,8
Inlet temperature		°C	48,0	44,0	36,0	34,9
CO ₂ measured		%	9,4	9,2	9,2	9,1
CO measured		ppm	50	44	34	30
COc (0% O ₂)		ppm	62	56	43	39
NOx measured		ppm	17	15	7	4
NOx adjusted		mg/kWh	37,33	33,65	15,70	9,07
NOx total		mg/kWh	21,44			
NOx adjusted		mg/kWh	18,09			
NOx class assigned			5			

NOx class	1	2	3	4	5
NOx limit	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 306

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO₂} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H₂O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
<u>MAX HEAT INPUT</u>		148,0 kW					
	G20	1,19	1	2	9,4	15,661	65,48
	G25	1,19	0,86	1,72	-----	18,215	-----
	G30	1,19	4	5	-----	4,590	-----
	G31	1,19	3	4	-----	6,055	-----
<u>MIN HEAT INPUT</u>		34,0 kW					
	G20	1,19	1	2	9,8	3,598	14,53
	G25	1,19	0,86	1,72	-----	4,185	-----
	G30	1,19	4	5	-----	1,054	-----
	G31	1,19	3	4	-----	1,391	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 306

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet ✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,6 340 375 2000					
Minimum heat input (only for gas/air ratio controls) 10,5 30 33 2000					
Intervention of APS before CO concentration exceed 2000ppm ----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 307

Dati nominali
Nominal data

Brand name	RIMA
Model	ONGAS 307
Installation type admitted	B23-C63
Registration number	Prototype
Burner adjusting	Modulating
Flame surveillance	Ionization
Ignition type	Electronic
<u>Heating circuit</u>	
Max temperature of heating water	110,0 °C
Max pressure of heating water (PMS)	6,0 bar
Heating water circulation	Forced
Pressure class	3
<u>Electrical nominal data</u>	
Input voltage	230 V
Frequency	50 Hz
Electrical power	315 W
Protection level against moistness and water inlet	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 307

Dati tecnici
Technical data

Nominal heat INPUT			
Maximum		kW	180,0
Minimum		kW	38,0
Efficiency			
Maximum heat input	(80-60°C)	%	95,1
Minimum heat input	(80-60°C)	%	96,6
Maximum heat input	(50-30°C)	%	103,7
Minimum heat input	(50-30°C)	%	109,5
Partial load return 30°C (direct method)		%	106,6
Fan speed			MAX MIN
G20		rpm	5200 900
CO2 content			MAX MIN
G20		%	9,30 9,20



Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

ONGAS 307

Configurazione camini
Flue instalation configuration

Flue installation

Installation type		B23-C63
Diameter of air inlet ducts	mm	115,0
Diameter of evacuation ducts	mm	150,0

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 307

BOILERS WITH PNEUMATIC AIR/GAS RATIO CONTROL	Test with water temperature: <u> x </u> 80 °C / 60 °C
8.4.1 Nominal heat input	<u> </u> 50 °C / 30 °C
8.12.2 Carbon monoxide - Limit conditions	
8.12.3 Carbon monoxide - Special conditions	

Gas group	2E	N° injectors	----	Installation type	B23
Reference gas	G20	Injectors diameter	---- mm	Type of ducts	separated
Nominal supply pressure	20,0 mbar	Gas diaphragm	---- mm	Evacuation ducts diameter	150 mm
		Diameter pilot burner injector	---- marking	Air inlet ducts diameter	115 mm

Test n°		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Ambient temperature	°C	24,1	23,2														
Ambient air speed	m/s	0,19	0,20														
Evacuation duct length	m	1,0	1,0														
Air inlet duct length	m	1,0	1,0														
Test gas		G20	G20	G20	G20	G20	G20	G20	G20	G21	G21	G20	G20	G20	G20	G231	G20
Gas supply pressure	mbar	20,0	20,0													17,0	20,0
Gas meter pressure	mbar	28,4	28,9													17,6	24,8
Fan speed	g/min	5200	900														2700
Reference gas "Net calorific value"	MJ/m ³	34,02	34,02	34,02	34,02	34,02	34,02	34,02	34,02	40,91	40,91	34,02	34,02	34,02	34,02	28,91	34,02
Used gas "Net calorific value"	MJ/m ³	34,10	34,10														34,10
Reference gas density		0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,555	0,687	0,687	0,555	0,555	0,555	0,555	0,617	0,555
Used gas density		0,555	0,555														0,555
Atmospheric pressure	mbar	1007	1007														1007
Gas temperature	°C	21,5	21,5														22,5
Gas meter type	a=wet, s=dry	s	s														s
Combustion air temperature	°C	23,5	23,4														24,1
Correction under reference conditions		1,0227	1,0230														1,0184
Meter correction		0,993	0,995														0,994
Gas volume	dm ³	600,0	70,0														100,0
Time	s	112,0	66,2														44,2
Measured heat input	kW	185,08	36,63														77,94
Measured heat input uncertainty	kW																
Nominal heat input	kW	180,00	38,00	180,00	38,00	180,00	38,00	180,00	38,00	180,00	38,00	180,00	38,00	180,00	38,00	38,00	78,00
Deviation		2,82%	-3,61%														-0,08%
Deviation with uncertainty		2,82%	-3,61%														-0,08%
Allowed deviation		±5%	±5%	----	----	----	----	----	----	----	----	----	----	----	----	----	< 0

Flue gas temperature	°C	55,6	52,1														
CO2 measured	%	9,3	9,2		10,2					10,4	11,0						7,3
CO measured	ppm	56	13		12					650	270						568
CO in dry air-free products combustion products	ppm	70	17		14					763	299						895
CO uncertainty	ppm	30	30		30					30	30						30
Limit	ppm	----	----	1000	1000	1000	1000	1000	1000	2000	2000	2000	2000	2000	2000	2000	----

Test n° Pt	Description
1 8.4.1	Maximum heat input
2 8.4.1	Minimum heat input
3 8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmax
4 8.12.2.102 b)	"Throttle" maladjustment for CO2 0,5% higher - Qmin
5 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmax
6 8.12.2.102 c)	Offset maladjustment for have +5 Pa - Qmin
7 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmax
8 8.12.2.102 c)	Offset maladjustment for have -5 Pa - Qmin
9 8.12.3.1	Incomplete combustion - Qmax
10 8.12.3.1	Incomplete combustion - Qmin
11 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmax
12 8.12.3.2	Supply electric voltage variation - 85% of nominal voltage - Qmin
13 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmax
14 8.12.3.2	Supply electric voltage variation - 110% of nominal voltage - Qmin
15 8.12.3.3	Flame lift limit gas
16 8.4.3	Ignition rate

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
 See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 307

9.2 - 9.3 USEFUL EFFICIENCIES

Maximum heat input	180,0	kW	Maximum heat output	180,0	kW
Minimum heat input	38,0	kW	Minimum heat output	38,0	kW
Average heat input	109,0	kW	Average heat output	109,0	kW
Range rated	yes				
Type of boiler	condensing				
Type of gas	G20		<u>Parameter for partial load test</u>		
Installation type	B23		Method	direct	
Evacuation duct diameter	150 mm		Operating mode	1,0	
Air inlet duct diameter	115 mm		Conditions	3,0	
Evacuation duct length	0,5 m		T _{ON}	528,0	sec
Air inlet duct length	0,5 m		T _{OFF}	72,0	sec
Diaphragm diameter	---- mm				

Test n°			1	2	3	4	5	6
Ambient temperature	°C		22,0	22,0	22,0	21,8	21,9	22,4
Relative humidity	%							
Specific humidity	g/kg		x	x	x	10,0	9,9	9,9
Atmospheric pressure	(Pa)	mbar	1009	1009	1009	1009	1009	1009
Net calorific value of used gas	(Hi)	MJ/m ³ st	34,02	34,02	34,02	34,02	34,02	34,02
Gas meter pressure	(Pg)	mbar	41,5	22,2	20,4	41,8	22,0	21,0
Gas temperature	(Tg)	°C	22,3	22,3	22,5	22,4	22,5	22,1
Gas meter correction			1,006	0,994	0,998	1,006	0,994	0,994
Gas volume		l	3150,0	660,0	1980,0	3210,0	680,0	601,8
Time		s	598,8	599,5	602,6	600,1	606,7	600,3
Measured heat input		kW	182,01	36,94	110,44	185,19	37,58	33,61
Loss at test bench	(Dp)	kJ	0,0	0,0	0,0	0,0	0,0	0,0
Water rate		kg/h	7457,9	1581,1	4574,4	8233,5	1800,3	4539,1
Return temperature		°C	60,1	60,0	59,7	30,1	30,0	30,0
Flow temperature		°C	80,1	79,4	79,6	50,1	49,6	36,8
ΔT measured			20,3	19,7	20,2	20,1	19,7	6,8
Power issued to water		kW	173,04	35,60	105,63	192,04	41,16	35,82
Water efficiency	%		95,1	96,4	95,6	103,7	109,5	106,6
Water efficiency uncertainty	%							

Test n° 1	Maximum heat input	80-60°C
Test n° 2	Minimum heat input	80-60°C
Test n° 3	Average heat input	80-60°C
Test n° 4	Maximum heat input	50-30°C
Test n° 5	Minimum heat input	50-30°C
Test n° 6	Partial load (30%) return 30°C	

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.2 Supervision of the combustion air rate or the combustion products rate

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	150/115	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO2 adjustment stated by the manufacturer:

	Qmax	Qmin
CO2 MAX	9,5%	9,1%
CO2 MIN	9,4%	9,0%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		8,9	14	18	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,8	130	155	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		8,5	342	471	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
		9,9	28	33	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO2 (%)	CO (ppm)	COc (0% O2) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

a) Adjust the CO₂ at Q_{max} to the MAX CO₂ value and at Q_{min} at MIN CO₂ value

Type of ducts	separated	Gas group	2E
Duct diameter (evacuation / air inlet)	150/115 mm	Reference gas	G20
Evacuation duct length	0,2 m	Nominal supply pressure	20 mbar
Air inlet duct length	0,2 m		

Manufacturer choice:

Continuous supervision	
Start up supervision	x

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,5%	9,1%
CO ₂ MIN	9,4%	9,0%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,2	128	242	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		5,8	107	216	1000
					1000
					1000
					1000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		10,5	27	30	1000
					1000
					1000
					1000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		8,9	18	24	1000
					1000
					1000
					1000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					1000
					1000
					1000
					1000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.11.101 AIR PROVING DEVICE

8.11.101.3 Gas/air ratio controls

8.11.101.3.3 Adjustment of the gas/air ratio

b) Adjust the CO₂ at Q_{max} to the MIN CO₂ value and at Q_{min} at MAX CO₂ value

Type of ducts	separated	
Duct diameter (evacuation / air inlet)	150/115	mm
Evacuation duct length	0,2	m
Air inlet duct length	0,2	m

Gas group	2E
Reference gas	G20
Nominal supply pressure	20 mbar

Manufacturer choice:

Continuous supervision	x
Start up supervision	

CO₂ adjustment stated by the manufacturer:

	Q _{max}	Q _{min}
CO ₂ MAX	9,5%	9,1%
CO ₂ MIN	9,4%	9,0%

a) Progressive blockage of the air inlet

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		10,7	278	303	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,3	32	60	2000
					2000
					2000
					2000

b) Progressive blockage of the combustion products evacuation ducts

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		11,3	1625	1683	2000
					2000
					2000
					2000

Blockage	Δp ducts (Pa)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
		6,0	47	92	2000
					2000
					2000
					2000

c) Progressive reduction of the fan speed

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Blockage	Fan voltage (V)	CO ₂ (%)	CO (ppm)	COc (0% O ₂) (ppm)	Limit
					2000
					2000
					2000
					2000

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

ONGAS 307

8.13 NOx EMISSION - (NITROGEN OXIDE - 20°C - Proportional moistness 10gH2O/kg air)
 8.13.2.5 / 8.13.2.6 Modulating boiler

Maximum heat input	Qn	180,0	kW
Minimum heat input	Qr	38,0	kW
Average heat input	Qa	109,0	kW
Range rated		yes	

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	150-115 mm
Length of drain pipe	0,5 m
Direction	-----
Diaphragm diameter	----- mm

Ambient temperature	T _{amb}	22,4	°C
Atmospheric pressure	P _{atm}	1009	mbar
Specific humidity		10,57	g/kg

			Qr			
Partial heat input Qpi in % of Qn			70%	60%	40%	35%
Partial heat input	Qpi	kW	76,3	65,4	43,6	38,0
Pondering factor	Fpi		0,15	0,25	0,30	0,30
Fan speed		g/min	3750	3750	3750	3750
Measured heat input		kW	77,7	65,8	45,1	38,0
Inlet temperature		°C	48,0	44,0	36,0	33,9
CO ₂ measured		%	9,7	9,6	9,5	9,2
CO measured		ppm	80	62	34	26
COc (0% O ₂)		ppm	96	76	42	33
NOx measured		ppm	29	25	11	4
NOx adjusted		mg/kWh	61,70	53,75	23,90	8,97
NOx total		mg/kWh	32,55			
NOx adjusted		mg/kWh	30,69			
NOx class assigned			5			

NOx class	1	2	3	4	5
NOx limit	260	200	150	100	70

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

OUTPUT MASS

		Volume of the mass of the combustion products at 15 °C	V _{CO2} : Carbon dioxide created by the combustion of 1 m ³ of gas with air	V _{H2O} : water steam created by the combustion of 1 m ³ of gas with air	CO ₂ measured	Output volume of the referring gas at the output heat indicated by the manufacturer at 15 °C and 1013,25 mbar under root adjusted also to the meter	Mf: Combustion products output mass
	Measure unit	kg/m ³	m ³ /m ³	m ³ /m ³	%	m ³ /h	g/sec
<u>MAX HEAT INPUT</u>		180,0 kW					
	G20	1,19	1	2	9,3	19,048	80,36
	G25	1,19	0,86	1,72	-----	22,154	-----
	G30	1,19	4	5	-----	5,582	-----
	G31	1,19	3	4	-----	7,364	-----
<u>MIN HEAT INPUT</u>		38,0 kW					
	G20	1,19	1	2	9,2	4,021	17,12
	G25	1,19	0,86	1,72	-----	4,677	-----
	G30	1,19	4	5	-----	1,178	-----
	G31	1,19	3	4	-----	1,555	-----

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Ignition	CO ₂ %	CO [ppm]	CO [ppm] in air and water free products of combustion	Limit [ppm]
8.6.3 Special flue conditions					
Tests at nominal and minimum heat input					
Reference gas used G20					
8.6.3.104 <u>Type C4</u>					
8.12.3.101.3 Shortest ducts specified by the manufacturer					
Suction of 0,5mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
8.6.3.105 <u>Type C5</u>					
8.12.3.101.4 Shortest ducts specified by the manufacturer					
Suction of 2,0mbar applied to the combustion products evacuation ducts					
Maximum heat input ----- 2000					
Minimum heat input ----- 2000					
<u>Type C6</u>					
8.6.3.106 Suction of 0,5mbar applied to the combustion products outlet ✓					
8.12.3.101.5 10% of the combustion products are recirculated in the air supply					
Maximum heat input 10,7 340 372 2000					
Minimum heat input (only for gas/air ratio controls) 10,6 22 24 2000					
Intervention of APS before CO concentration exceed 2000ppm ----- 2000					
APS switch off at ----- Pa					
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

10 ELECTRIC AUXILIARY ENERGY

	Unit	Measured
<p>10.2 The system boundary contains all electrical components between the manual shut-off device and the flue outlet of the combustion circuit, <u>including the circulation pump.</u></p>		
<p>10.3 Auxiliary energy at nominal heat input</p> <p>Test conditions as pt. 9.2.2 The external hydraulic resistance is adjusted in such a way that is 0,15 bar at 20 K temperature difference</p>		
<u>Measured auxiliary energy</u>	kW	0,3150
<p>10.4 Auxiliary energy at part load</p> <p>Test conditions as pt. 9.2.2 and 9.3.2</p>		
<u>Measured auxiliary energy</u>	kW	0,0360
<p>10.5 Auxiliary energy at stand-by</p> <p>Power input measured during operation in stand-by</p>		
<u>Measured auxiliary energy</u>	kW	0,0042

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.5 LIMITING TEMPERATURES

	Measured	Limit
8.5 Limiting temperatures		
8.5.1 Reference gas - Nominal heat input Control thermostat set at maximum The temperature are measured when thermal equilibrium is reached		
Ambient temperature	24,0 °C	
8.5.2 Adjusting, control and safety devices		
Gas valve	29,0 °C	°C
PCB electronic card	36,0 °C	°C
Venturi	30,0 °C	°C
Knobs		
Metal	----- K	35 K
Glass and ceramics	----- K	45 K
Plastic	5,0 K	60 K
8.5.3 Side walls, front and top surface		
Side wall	10,0 K	80 K
Front surface	9,0 K	80 K
Top surface	8,0 K	80 K
8.5.4 Test panels and floor		
Floor	x K	80 K *
Right panel	4,0 K	80 K *
Left panel	4,0 K	80 K *
Back panel	8,0 K	80 K *
* if temperature rise is between 60 K and 80 K the manufacturer shall supply a protection		
8.5.101 External temperature of the ducts The temperature are measured after 30 min		
External temperature of the ducts	45,0 K	60 K

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

ONGAS 307

8.11.6 FLAME SUPERVISION DEVICE

8.11.6.2 Automatic burner control system

8.11.6.2.2 Extinction safety time TSE

Reference gas
Normal pressure

The boiler operate for at least 10 min at nominal heat input

Qn: 90,0 kW

Test gas		G20							
Gas inlet pressure	mbar	28,4							
Measured extinction safety time	s	1,00							
Limit	s	3,00	3,00	3,00	3,00	3,00	3,00	3,00	3,00

*General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%.
See enclosure n°1 for the equipment uncertainty*

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.11.6 FLAME SUPERVISION DEVICE

8.11.6.2 Automatic burner control system

8.11.6.2.1 Ignition safety time TSA

Reference gas
 Normal pressure
 Extreme conditions of electrical supply

Qn: 90,0 kW
 Qignition: 36,0 kW

Test gas		G20							
Gas inlet pressure	mbar	28,4							
Measured ignition safety time	s	1,00							
Limit	s	10,00	10,00	10,00	10,00	10,00	10,00	10,00	10,00

General note: The measurement uncertainties reported in this document have been estimated as expanded uncertainty obtained multiplying the standard uncertainty by the coverage factor K=2 corresponding to a confidence level of about 95%. See enclosure n°1 for the equipment uncertainty

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.12.5 Supplementary test for low temperature boilers and condensing boilers

8.12.5 Condensate discharge blockage

Functioning at nominal rate with condensate discharge blocked

Type of gas	G20
Installation type	B23
Diameter of pipe (outlet-inlet)	x
Length of ducts	1,0
Direction	-----
Diaphragm diameter	-----

The boiler shall meet one of the following requirements:

- | | |
|--|-------|
| a) <u>the gas supply shut off before the CO concentration exceeds 2000ppm</u> | ✓ |
| b) <u>restart is not possible from cold whit condensate discharge blocked that cause a restriction in the flow of combustion products or air for combustion that result in a CO concentration \geq 1000ppm at equilibrium</u> | ----- |

✓ = Conformity

NC = Not in conformity

----- = Not applicable

x = Not done

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.11.8 THERMOSTATS AND WATER TEMPERATURE LIMITING DEVICES

	Declared value °C	Measured value °C	Difference °C	Limit		
8.11.8.1 Water control thermostat						
a) Maximum setting temperature	85,0	87,0	2,0	± 10	✓	
b) Minimum setting temperature	85,0	86,5	1,5	± 10	✓	
c) Maximum flow temperature	110,0	94,0	-16,0	< 0	✓	
8.16.102.1	Nominal working combustion products temperature (test a)	90,0	88,0	-2,0	< 0	✓
8.11.8.2 Water temperature limiting device						
<u>8.11.8.2.1 Inadequate water circulation</u>						
Water rate progressively reduced for temperature increase of 2 K/min						
No deterioration of the boiler						✓
<u>8.11.8.2.2 Overheating of boilers of pressure classes 1 and 2</u>						
Test n° 1:						
Control thermostat out of service						
Boiler cold water rate progressively reduced for temperature increase of 2 K/min						
Water temperature measured						-----
Overheat combustion products temperature						-----
Safety shutdown						-----
Test n° 2:						
Control thermostat out of service						
Temperature limiter out of service						
Boiler cold water rate progressively reduced for temperature increase of 2 K/min						
Water temperature measured						-----
Overheat combustion products temperature						-----
Non volatile lockout						-----
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done						

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.11.8 THERMOSTATS AND WATER TEMPERATURE LIMITING DEVICES

	Declared value °C	Measured value °C	Difference °C	Limit	
<u>8.11.8.2.3 Overheating of boilers of pressure classes 3</u>					
Test n° 1: Control thermostat out of service					
Boiler cold water rate progressively reduced for temperature increase of 2 K/min					
Water temperature measured		90,0		110°C	✓
Safety shutdown					✓
Test n° 2: Control thermostat out of service Temperature limiter out of service					
Boiler cold water rate progressively reduced for temperature increase of 2 K/min					
Water temperature measured		89,5		110°C	✓
Non volatile lockout					✓
Test n° 3 (only if temperature exceed 110°C during test n°2): Control thermostat out of service					
Boiler cold water rate progressively reduced for temperature increase of 2 K/min					
Water temperature measured		-----		110°C	-----
Safety shutdown					-----
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done					



Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report n° **TIQG-19-009**

8.16 Temperature of combustion products

8.16 Temperature of combustion products	
Maximum temperature of the combustion products measured	85,0 °C
Non volatile lockout	✓

✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Test Gas	Gas supply pressure mbar	Ambient temperature	Thermal equilibrium
8.6.1 Tests at ambient temperature and at thermal equilibrium				
8.6.2 Limit conditions				
Test n°1				
Reference gas				
Tests at nominal and reduced heat input				
Minimum pressure	G30	25,0	----	----
	G30	25,0	----	----
	G30	42,5	----	----
70% of normal pressure	G20	14,0	✓	✓
	G25	17,5	----	----
	G25	14,0	----	----
	G20	17,5	----	----
	G25.1	17,5	----	----
	G2.350	9,1	----	----
	G27	14,0	----	----
	G230	14,0	----	----
Test n°2				
Light back limit gas				
Tests at nominal and reduced heat input				
Minimum pressure	G32	25,0	----	----
	G32	25,0	----	----
	G32	42,5	----	----
	G222	17,0	✓	✓
	G25	20,0	----	----
	G25	17,0	----	----
	G222	18,0	----	----
	G25.1	18,0	----	----
	G2.352	10,0	----	----
	G2.412	17,0	----	----
	G232	17,0	----	----
Test for PL	G222	16,0		
Test for RO	G222	15,0		
✓ = Conformity NC = Not in conformity ---- = Not applicable x = Not done				

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Test Gas	Gas supply pressure mbar	Ambient temperature	Thermal equilibrium	
Test n°3 Flame lift limit gas Tests at nominal and reduced heat input Minimum pressure	G31	25,0	-----	-----	
	G31	25,0	-----	-----	
	G31	42,5	-----	-----	
	G23	17,0	✓	✓	
	G231	17,0	✓	✓	
	G27	20,0	-----	-----	
	G271	17,0	-----	-----	
	G23	18,0	-----	-----	
	G27.1	18,0	-----	-----	
	G2.352	10,0	-----	-----	
	G2.412	17,0	-----	-----	
	G230	17,0	-----	-----	
	Test for BE	G231	15,0	✓	✓
	Test n°4 Flame lift limit gas Maximum pressure	G31	45,0	-----	-----
G31		45,0	-----	-----	
G31		57,5	-----	-----	
G23		25,0	✓	✓	
G231		30,0	✓	✓	
G27		30,0	-----	-----	
G271		25,0	-----	-----	
G23		33,0	-----	-----	
G27.1		33,0	-----	-----	
G2.352		16,0	-----	-----	
G2.412		23,0	-----	-----	
G230		25,0	-----	-----	

✓ = Conformity

NC = Not in conformity

----- = Not applicable

x = Not done

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Test Gas	Gas supply pressure mbar	Result
Test N°5 (only if indirect means of indicating the presence of flame)			
Flame lift limit gas			
Normal pressure	G31	29,0	-----
Thermal equilibrium	G31	37,0	-----
	G31	50,0	-----
CO content < 1000 ppm	G23	20,0	✓
	G231	20,0	✓
	G27	25,0	-----
	G271	20,0	-----
	G23	25,0	-----
	G27.1	25,0	-----
	G2.352	8,0	-----
	G2.412	20,0	-----
	G230	20,0	-----
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done			

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.6 IGNITION, CROSS-LIGHTING, FLAME STABILITY

	Test Gas	Gas supply pressure mbar	Result
8.6.4 Reduction of the gas rate of ignition burner			
Ignition rate reduced to give the minimum energy necessary to keep the gas way to burner open	G30	25,0	-----
	G30	25,0	-----
Ignition without damage to the boiler	G30	42,5	-----
	G20	17,0	✓
	G25	20,0	-----
	G25	17,0	-----
	G20	18,0	-----
	G25.1	18,0	-----
	G2.350	10,0	-----
	G27	17,0	-----
G230	17,0	-----	
8.6.101 <u>Resistance to draught for type B boilers</u>			
Reference gas	G30	29,0	-----
Nominal heat input	G30	37,0	-----
	G30	50,0	-----
Wind of 2m/s at burner level	G20	20,0	✓
	G25	20,0	-----
	G25	25,0	-----
	G20	25,0	-----
	G25.1	25,0	-----
	G2.350	25,0	-----
	G27	8,0	-----
	G230	20,0	-----
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done			

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report N° **TIQG-19-009**

8.2 SOUNDNESS

	cm	cm ³	sec	Measured leakage cm ³ /h	Limit cm ³ /h	
8.2.1 Soundness of the gas circuit						
Upstream pressure: 50,0 mbar						
Delivery condition	*	*	*	*	140	✓
At the end of the tests	*	*	*	*	140	✓
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done						

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

--

	Test Gas	Gas supply pressure mbar	Result
<p>8.7 Reduction of the gas rate pressure</p> <p>Reference gas The boiler supply pressure is progressively reduced (from 70% of the normal pressure to 0 mbar)</p> <p>No dangerous situation for the user or damage to the boiler</p>			
	G30	20,3	-----
	G30	25,9	-----
	G30	35,0	-----
	G20	14,0	✓
	G25	14,0	-----
	G25	17,5	-----
	G20	14,0	-----
	G25.1	17,5	-----
	G2.350	17,5	-----
	G27	5,6	-----
	G230	14,0	-----
<p>8.8 Defective closure of the gas valve (only if the gas line is designed such that the gas supply to the ignition burner is taken from between the two main burner gas valves)</p> <p>Reference gas Normal inlet pressure</p>			
	G30	29,0	-----
	G30	37,0	-----
	G30	50,0	-----
	G20	20,0	-----
	G25	20,0	-----
	G25	25,0	-----
	G20	20,0	-----
	G25.1	25,0	-----
	G2.350	25,0	-----
	G27	8,0	-----
	G230	20,0	-----
<p>✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done</p>			

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.11 ADJUSTMENT, CONTROL AND SAFETY DEVICES

	Test Gas	Gas supply pressure mbar	Result
8.11.4 Control devices			
8.11.4.1 Rotary knob			
Operating torques of a knob shall not exceed 0,6 N.m or 0,017 N.m/mm of knob diameter			✓
8.11.4.2 Push-button			
Force required to open and/or to keep open the closure element shall not exceed 45 N or 0,5 N/mm ² of the are of the button			✓
8.11.5 Ignition devices			
8.11.5.1 Manual ignition device for ignition burner			
Ambient temperature	G30	29,0	-----
Reference gas	G30	37,0	-----
Max temperature which the ignition device is subjected in the boiler	G30	50,0	-----
Voltage varied between 0,85 and 1,1 times the nominal voltage	G20	20,0	-----
	G25	20,0	-----
The ignition device is operated 40 times (with intervals of at least 1,5s)	G25	25,0	-----
	G20	25,0	-----
At least 50% of the manual ignition attempts shall result in correct ignition	G25.1	25,0	-----
	G2.350	8,0	-----
	G27	20,0	-----
	G230	20,0	-----
8.11.5.2 Automatic ignition system for the ignition burner and main burner			
8.11.5.2.1 General			
Ignition shall be effected within a maximum of 5 automatic ignition attempts			✓
8.11.5.2.2 Ignition			
Reference gas	G30	29,0	-----
Normal pressure	G30	37,0	-----
Voltage of 0,85 times the nominal voltage	G30	50,0	-----
	G20	20,0	✓
	G25	20,0	-----
- 20 ignition attempts (waiting time of 30s) at ambient temperature	G25	25,0	-----
- 20 ignition attempts (waiting time of 30s) at thermal equilibrium	G20	25,0	-----
	G25.1	25,0	-----
	G2.350	8,0	-----
	G27	20,0	-----
	G230	20,0	-----
✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done			

Manufacturer **ON METAL DOKUM SAN. VE TIC.**
 Model **ONGAS 303...307**
 Test report n° **TIQG-19-009**

8.12.4 SOOTING

	Test Gas	Gas supply pressure mbar	
<p>8.12.4 Sooting</p> <p>Functioning with sooting limit gas for:</p> <p>a) 1h in the case of boilers with heat inputs ≤ 70 kW</p> <p>b) 15 min in the case of boilers with heat inputs > 70 kW</p> <p>No soot deposition shall be observed (yellow tipping is acceptable)</p>	G30	29	-----
	G30	37	-----
	G30	50	-----
	G21	20	✓
	G26	25	-----
	G26	20	-----
	G21	25	-----
	G26.1	25	-----
	G2.351	13	-----
	G2.411	20	-----
	G233	20	-----
	<p>✓ = Conformity NC = Not in conformity ----- = Not applicable x = Not done</p>		



Manufacturer **ON METAL DOKUM SAN. VE TIC.**
Model **ONGAS 303...307**
Test report N° **TIQG-19-009**

Fine del rapporto di prova
End of test report

SHORT DESCRIPTION OF THE APPLIANCES

The appliance to test are gas hobs with the following technical characteristics:

Model	Maximum heat input (kW)	Minimum heat input (kW)	Maximum heat output (kW)	Minimum heat output (kW)	Diameter of air inlet duct (mm)	Diameter of evacuation duct (mm)
ONGAS 303	65	15	62	14	50	80
ONGAS 304	90	20	87,8	18,9	80	100
ONGAS 304 PLUS	110	20	107	19,5	60	100
ONGAS 305	119	19	114,7	18	80	115
ONGAS 306	148	34	142,1	32,7	115	130
ONGAS 307	180	38	171,2	36,6	115	150
ONGAS 303/W	65	15	62	14	50	80
ONGAS 304/W	90	20	87,8	18,9	80	100
ONGAS 304/W PLUS	110	20	107	19,5	60	100
ONGAS 305/W	119	19	114,7	18	80	115
ONGAS 306/W	148	34	142,1	32,7	115	130
ONGAS 307/W	180	38	171,2	36,6	115	150

Tests have been performed on the models ONGAS 303, ONGAS 304, ONGAS 304 PLUS, ONGAS 305, ONGAS 306 and ONGAS 307 which covers all the models foreseen.

The appliances are expected to be traded in the following Countries with the relative gas categories:

Country	Category	Gas type	Pressure (mbar)
AL	ALBANIA	I2H	20
AT	AUSTRIA	I2H	20
BE	BELGIUM	I2E(R)	20
BG	BULGARIA	I2H	20
CY	CYPRUS	I2H	20
HR	CROATIA	I2H	20
DK	DENMARK	I2H	20
EE	ESTONIA	I2H	20
FI	FINLAND	I2H	20
FR	FRANCE	I2Er	20/25
DE	GERMANY	I2E	20
GR	GREECE	I2H	20
IE	IRELAND	I2H	20
IT	ITALY	I2H	20

Enclosure 1 to T.R. TIQG-19-009

LV	LATVIA	I2H	G20	20
LT	LITHUANIA	I2H	G20	20
LU	LUXEMBOURG	I2E	G20	20
NO	NORWAY	I2H	G20	20
PL	POLAND	I2E	G20	20
PT	PORTUGAL	I2H	G20	20
GB	UNITED KINGDOM	I2H	G20	20
CZ	CZECH REPUBLIC	I2H	G20	20
MK	REPUBLIC OF MACEDONIA	I2H	G20	20
RO	ROMANIA	I2H I2E	G20 G20	20 20
SK	SLOVAKIA	I2H	G20	20
SI	SLOVENIA	I2H	G20	20
ES	SPAIN	I2H	G20	20
SE	SWEDEN	I2H	G20	20
CH	SWITZERLAND	I2H	G20	20
TR	TURKEY	I2H	G20	20